

CircuitSolver® Union Assembly Thermal Disinfection Dual Valve with Viega ProPress® Systems (CSUATD-D-PP) [Thermostatic balancing valve with union body, ball valves, ProPress ends & two actuators]

SUBMITTAL

JOB:	ORDER NO:	DATE:
	SUBMITTED BY:	DATE:
UNIT TAG:	APPROVED BY:	DATE:
CITY:	ENGINEER:	BUILDING TYPE:
STATE:	CONTRACTOR:	CONSTRUCTION TYPE:
COMPLETION DATE:		

DESCRIPTION


CircuitSolver® is a thermostatic balancing valve that automatically and continuously adjusts flow to maintain the desired temperature in a domestic hot water supply line. Since the CircuitSolver® responds to water temperature to control the flow entering the recirculation line it eliminates the need to manually balance the system. The "CSUATD-D-PP" version CircuitSolver® incorporates a second actuator to reopen the valve during a thermal disinfection process, an optional check valve, isolated ball valves, and Viega® ProPress adapter fittings.


DIMENSIONS

Iten No.	Part Number	Description	Qty.
1	261-20X00X-XXX	CSUTD-D-1/2-XXX/ YYY-(CV1)	1
2	92-160	BALL VALVE, ½" MxF, LF	1
3	92-090	ADAPTER, ½" NPT x ½" ProPress	2

Item No.	Part Number	Description	Qty.
1	261-30X00X-XXX	CSUTD-D-3/4-XXX/ YYY-(CV1)	1
2	92-158	BALL VALVE, ¾" MxF, LF	1
3	92-091	ADAPTER, ¾" NPT x ¾" ProPress	2

Item No.	Part Number	Description	Qty.
1	261-40X00X-XXX	CSUTD-D-1-XXX/YYY- (CV1)	1
2	92-170	BALL VALVE, 1" MxF, LF	1
3	92-092	ADAPTER, 1" NPT x 1" ProPress	2





		Diameter (D)		Length (L)		Height (H)		Weight		Standard Balancing C _v			Thermal Disinfection Balancing C _v		Maximum Operating Pressure		Maximum Temperature	
Model No.	NPT	IN	MM	IN	ММ	IN	ММ	LBS	KG	OPEN	CLOSED	DESIGN	OPEN	CLOSED	PSIG	BAR	°F	°C
CSUATD-D-½-XXX/170-PP	1/2"	2.0	51	12.7	323	1.8	46	3.8	1.7	1.2	0.2	0.60	0.5	0.2				
CSUATD-D-1/2-XXX/170-CV1-PP	1/2	2.0	51	12.7	323	1.8	46	3.8	1.7	1.2	0.2	0.60	0.5	0.2				
CSUATD-D-3/4-XXX/170-PP	3/4"	2.0	51	13.7	348	2.0	51	4.5	2.0	1.2	0.2	0.85	0.5	0.2	200	14	250	121
CSUATD-D-3/4-XXX/170-CV1-PP	3/4	2.0	51	13.7	340	2.0	51	4.5	2.0	1.2	0.2	0.65	0.5	0.2	200		200	121
CSUATD-D-1-XXX/170-PP	1"	2.4	60	15.2	386	2.3	59	7.0	3.2	2.0	0.2	1.57	0.8	0.2				
CSUATD-D-1-XXX/170-CV1-PP] '	2.4	80	15.2	300	2.3	1 59	7.0	3.2	2.0	0.2	1.57	0.6	0.2				

Model Number Selection


XXX refers to the desired closing temperature for standard balancing. When the water temperature drops below this point the CircuitSolver® will begin to open, allowing water to easily enter the return line. The valve will start to reopen approximately 20°F above the standard balancing temperature and rebalance the system at 170°F. For example, if you want 120°F desired return temperature and the CSUATD-D-PP is to be installed on a 3/4" line, the model number would be CSUATD-D-3/4-120-170-PP. To add optional check valve insert -CV1 to the end of the model number. Ex. CSUATD-D-3/4-120-170-CV1-PP


^{*}ALL COMPONENTS ARE LEAD FREE

^{*}ALL COMPONENTS ARE LEAD FREE

^{*}ALL COMPONENTS ARE LEAD FREE







Features and Benefits						
-100% factory tested drip tight operation						
-Snap fit design, no retainer needed						
-Extra-low head loss and low cracking pressure						
-External O-ring in	groove					
Certifications						
-ANSI/ NSF 61						
ITEM MATERIAL						
Сар	Glass filled Noryl					
Guide	Guide Glass filled Noryl					
Plunger	Glass filled Noryl					
Lip Spring	EPDM rubber					
Spring	Stainless Steel AISI 301					
O-ring EPDM rubber						
OPTIONAL CHECK VALVE TECHNICAL DATA						
Medium: Clear water only						

Short-term (5 minutes max.)

Approximate Cracking Pressure: 0.29 PSI

Continuous

OPTIONAL CHECK VALVE

FLOW RATE CALCULATION USING "Cv" FACTOR						
$GPM = C_v \sqrt{\Delta P}$	$C_V = \sqrt{\Delta P}$	$\Delta P = \left[\frac{GPM}{C_V}\right]^2$				

TYPICAL SPECIFICATION

- I. Furnish and install CIRCUITSOLVER® as indicated on the plans. CIRCUITSOLVER® shall be self-contained and fully automatic without additional piping or control mechanisms. Valve shall be a CIRCUITSOLVER® as manufactured by ThermOmegaTech®, Inc. or equivalent.
 - A. CIRCUITSOLVER® shall regulate the flow of recirculated domestic hot water based on water temperature entering the CIRCUITSOLVER® regardless of system operating pressure. As the water temperature increases the valve proportionally closes dynamically adjusting flow to meet the specified temperature.
 - 1. CIRCUITSOLVER® never fully closes, even at the desired set point. There is always sufficient bypass flow back to the recirculating pump to prevent overheating or "dead heading" of the pump.
 - 2. CIRCUITSOLVER® is set at the factory for the desired return temperature. No field adjustments needed. Several temperature set points are available.
 - 3. CIRCUITSOLVER® Union Assembly Thermal Disinfection Dual Balancing Valve shall be available in 1/2", 3/4" & 1" NPT with Viega ProPress adapter fittings at both ends.
 - B. CIRCUITSOLVER® Union Assembly Thermal Disinfection Dual Balancing Valve with ProPress adapters allows for an additional balancing cycle at 170°F.
 - 1. The valve will start to re-open above the low temperature balancing set point to allow high temperature water through during a thermal disinfection process. The valve will rebalance at the second temperature set point.
- II. CIRCUITSOLVER® body and all internal components are made with lead-free materials with major components constructed of type 300 series SS.
 - A. CIRCUITSOLVER® shall be rated to 200 PSIG maximum working pressure.
 - 1. CIRCUITSOLVER® shall be standard tapered female pipe thread, NPT, with ProPress adapter fittings at both ends.
 - B. CIRCUITSOLVER® shall be rated to 250°F (121.1°C) maximum working temperature.
 - C. Thermal actuator shall be spring-loaded and self-cleaning, delivering closing thrust sufficient to keep orifice opening free of scale deposits.
- III. Installation of CIRCUITSOLVER® shall be made by qualified tradesmen. Install CIRCUITSOLVER® in each domestic hot water return piping branch beyond last hot water device in that branch.
 - A. Provide suitable line size isolation valves, unions, and strainer as indicated in piping detail shown on the drawings.
 - B. Provide suitable access panel as required in non-accessible ceilings and walls.
 - C. Pay close attention to flow arrow, especially with valves that have an integrated check valve.

