

## CircuitSolver® Union Assembly Thermal Disinfection Dual Valve with Thermometer (CSUATD-D-TW)

[Thermostatic balancing valve with union body, ball valves, thermometer, and two actuators]

### **SUBMITTAL**

JOB:	ORDER NO:	DATE:
	SUBMITTED BY:	DATE:
UNIT TAG:	APPROVED BY:	DATE:
CITY:	ENGINEER:	BUILDING TYPE:
STATE:	CONTRACTOR:	CONSTRUCTION TYPE:
COMPLETION DATE:		

# **DESCRIPTION**


CircuitSolver® is a thermostatic balancing valve that automatically and continuously adjusts flow to maintain the desired temperature in a domestic hot water supply line. Since the CircuitSolver® responds to water temperature to control the flow entering the recirculation line it eliminates the need to manually balance the system. The "CSUATD-D-TW" version CircuitSolver® incorporates an optional check valve, isolated ball valves, a thermometer, and a second actuator to reopen the valve during a thermal disinfection process.


### **DIMENSIONS**

Item No.	Part Number	Description	Qty.		Item No.	Part Nu
1	261-20X00X-XXX	CSUTD-D-1/2-XXX/ YYY-(CV1)	1		1	261-30X0
2	92-160	BALL VALVE, ½" MxF, LF	2		2	92-1
3	92-162	½" X CL NIPPLE BRS LF	1		3	92-0
4	93-172	½″ TEE	1		4	93-1
5	93-094	THERMOWELL	1		5	93-0
6	94-287	THERMOMETER	1		6	94-2

Item No.	Part Number	Description	Qty.
1	261-30X00X-XXX	CSUTD-D-3/4-XXX/ YYY-(CV1)	1
2	92-158	BALL VALVE, ¾" MxF, LF	2
3	92-026	¾" X CL NIPPLE BRS LF	1
4	93-173	%" X ½"TEE	1
5	93-094	THERMOWELL	1
6	94-287	THERMOMETER	1

Item No.	Part Number	Description	Qty.
1	261-40X00X-XXX	CSUTD-D-1-XXX/YYY- (CV1)	1
2	92-170	BALL VALVE, 1" MxF, LF	2
3	92-044	1" X CL NIPPLE BRS LF	1
4	93-174	1" X ½"TEE	1
5	93-094	THERMOWELL	1
6	94-287	THERMOMETER	1






\*ALL COMPONENTS ARE LEAD FREE

F				-L-					1									
			neter D)	Leng	th (L)	Heigl	ht (H)	Wei	ght	Star	ndard Balan	cing C <sub>v</sub>		isinfection cing C <sub>v</sub>	Maximum Pres	Operating sure		mum erature
Model No.	NPT	IN	ММ	IN	MM	IN	ММ	LBS.	KG	OPEN	CLOSED	DESIGN	OPEN	CLOSED	PSIG	BAR	F°	C°
CSUATD-D-1/2-XXX/170-TW	1/2"	2.0	51	12.4	315	2.7	69	4.4	2.0	1.2	0.2	0.60	0.5	0.2				
CSUATD-D-½-XXX/170-CV1-TW	1/2	2.0	) 51	12.4	315	2.7	69	4.4	2.0	1.2	0.2	0.60	0.5	0.2				
CSUATD-D-%-XXX/170-TW	3/4"	2.0	51	13.4	340	2.8	71	4.8	2.2	1.2	0.2	0.85	0.5	0.2	200	14	250	121
CSUATD-D-%-XXX/170-CV1-TW	3/4	2.0	51	13.4	340	2.8		4.8	2.2	1.2	0.2	0.85	0.5	0.2	200	14	250	121
CSUATD-D-1-XXX/170-TW	1,,,	2.4	60	14.8	376	3.0	. 7.0	7.5	3.4	2.0		1.55	0.8	0.2				
CSUATD-D-1-XXX/170-CV1-TW	] '	2.4	80	14.8	3/6	3.0	76	7.5	3.4	2.0	0.2	1.57	0.8	0.2				

#### Model Number Selection

XXX refers to the desired closing temperature for standard balancing. When the water temperature drops below this point the CircuitSolver® will begin to open, allowing water to easily enter the return line. The valve will start to reopen approximately 20°F above the standard balancing temperature and rebalance the system at 170°F. For example, if you want 120°F desired return temperature and the CSUATD-D-TW is to be installed on a 3/4" line, the model number would be CSUATD-D-3/4-120-170-TW. To add optional check valve insert -CV1 to the end of the model number. Ex. CSUATD-D-3/4-120-170-CV1-TW





**OPTIONAL CHECK VALVE** 


-100% factory tested drip tight operation

Features and Benefits

Medium: Clear water only


Approximate Cracking Pressure: 0.29 PSI

Continuous



-Snap fit design, no retainer needed -Extra-low head loss and low cracking pressure -External O-ring in groove Certifications -ANSI/ NSF 61						
ITEM	MATERIAL					
Сар	Glass filled Noryl					
Guide	Glass filled Noryl					
Plunger	Glass filled Noryl					
Lip Spring	EPDM rubber					
Spring	Stainless Steel AISI 301					
O-ring EPDM rubber						
OPTIONAL CHECK VALVE TECHNICAL DATA						
·						

Short-term (5 minutes max.)



#### TYPICAL SPECIFICATION

- I. Furnish and install CIRCUITSOLVER® as indicated on the plans. CIRCUITSOLVER® shall be self-contained and fully automatic without additional piping or control mechanisms. Valve shall be a CIRCUITSOLVER® as manufactured by ThermOmegaTech®, Inc. or equivalent.
  - A. CIRCUITSOLVER® shall regulate the flow of recirculated domestic hot water based on water temperature entering the CIRCUITSOLVER® regardless of system operating pressure. As the water temperature increases the valve proportionally closes dynamically adjusting flow to meet the specified temperature.
    - 1. CIRCUITSOLVER® never fully closes, even at the desired set point. There is always sufficient bypass flow back to the recirculating pump to prevent overheating or "dead heading" of the pump.
    - 2. CIRCUITSOLVER® is set at the factory for the desired return temperature. No field adjustments needed. Several temperature set points are available.
    - 3. CIRCUITSOLVER® Union Assembly Thermal Disinfection Dual Balancing Valve with thermometer shall be available in 1/2", 3/4" & 1" NPT.
  - B. CIRCUITSOLVER® Union Assembly Thermal Disinfection Dual Balancing Valve with thermometer allows for an additional balancing cycle at 170°F.
    - 1. The valve will start to re-open above the low temperature balancing set point to allow high temperature water through during a thermal disinfection process. The valve will rebalance at the second temperature set point.
- II. CIRCUITSOLVER® body and all internal components are made with lead-free materials with major components constructed of type 300 series SS.
  - A. CIRCUITSOLVER® shall be rated to 200 PSIG maximum working pressure.
    - 1. CIRCUITSOLVER® shall be standard tapered female pipe thread NPT.
  - B. CIRCUITSOLVER® shall be rated to 250°F (121.1°C) maximum working temperature.
  - C. Thermal actuator shall be spring-loaded and self-cleaning, delivering closing thrust sufficient to keep orifice opening free of scale deposits.
- III. Installation of CIRCUITSOLVER® shall be made by qualified tradesmen. Install CIRCUITSOLVER® in each domestic hot water return piping branch beyond last hot water device in that branch.
  - A. Provide suitable line size isolation valves, unions, and strainer as indicated in piping detail shown on the drawings.
  - B. Provide suitable access panel as required in non-accessible ceilings and walls.
  - C. Pay close attention to flow arrow, especially with valves that have an integrated check valve.

