

# CircuitSolver® Union Assembly with Thermometer & Uponor ProPEX® Systems (CSUA-PX-TW)

[Thermostatic balancing valve with union body, ball valves, thermometer & ProPEX ends]

### **SUBMITTAL**

JOB:	ORDER NO:	DATE:
	SUBMITTED BY:	DATE:
UNIT TAG:	APPROVED BY:	DATE:
CITY:	ENGINEER:	BUILDING TYPE:
STATE:	CONTRACTOR:	CONSTRUCTION TYPE:
COMPLETION DATE:		

## **DESCRIPTION**

The CircuitSolver® Union Assembly with Thermometer's primary component is the CircuitSolver® which is a self-acting thermostatic recirculation valve that automatically and continuously maintains the end of each domestic hot water supply line at the specified water temperature. Since the CircuitSolver® responds to water temperature and controls flow to the return, it eliminates the need to manually balance the system.


### **DIMENSIONS**


Item No.	Part Number	Description	Qty.	Item No.	Part Number	Description	Qty.	Item No.	Part Number	Description	Qty.
1	258-20X100-XXX	1/2" CircuitSolver Thermostatic Balancing Valve With Integrated Union	1	1	258-30X100-XXX	3/4" CircuitSolver Thermostatic Balancing Valve With Integrated Union	1	1	258-40X100-XXX	1" CircuitSolver Thermostatic Balancing Valve With Integrated Union	1
2	92-116	1/2" PXM Adapter	2	2	92-093	3/4" PXM Adapter	2	2	92-117	1" PXM Adapter	2
3	92-160	Ball Valve, 1/2" MxF, Lead Free	2	3	92-158	Ball Valve, 3/4" MxF, Lead Free	2	3	92-170	Ball Valve, 1" MxF, Lead Free	2
4	92-162	1/2" x CL Nipple Brass	1	4	92-026	3/4" x CL Nipple Brass	1	4	92-044	1" x CL Nipple Brass	1
5	93-094-S	Thermowell Assembly	1	5	93-094-S	Thermowell Assembly	1	5	93-094-S	Thermowell Assembly	1
6	93-172	1/2" Tee, Brass	1	6	93-173	3/4" Tee, Brass	1	6	93-174	1" Tee, Brass	1

\*ALL COMPONENTS ARE LEAD-FREE

\*ALL COMPONENTS ARE LEAD-FREE

\*ALL COMPONENTS ARE LEAD-FREE






		Diame	eter (D)	Leng	th (L)	Heig	ht (H)	We	ight		$C_{v}$		Max. P	ressure	Max.	Temp.																						
Model No.	NPT	IN	MM	IN	MM	IN	MM	LBS.	KG	OPEN	CLOSED	DESIGN	PSIG	BAR	°F	°C																						
CSUA- ½ -XXX-PX-TW	1/2"	1.7	43	11.9	302	2.6	66	3.0	1.4	1.3	0.2	0.60																										
CSUA- ½ -XXX-CV1-PX-TW																																						
CSUA- ¾ -XXX-PX-TW	3/4"	2.0	51	14.2	361	2.9	74	4.3	1.9	1.8	0.2	0.85	200	14	250	121																						
CSUA- ¾ -XXX-CV1-PX-TW	3/4	2.0	31	91	91	01	01	51	51	51	51	51	51	51	51	51	51	51	וטו	51	51	) 31	31	01	51	14.2	301	2.9	/4	4.3	1.9	1.8	0.2	0.85	200	14	250	121
CSUA-1-XXX-PX-TW	1″	2.4	2.4 61	16.2	411	3.0	76	7.3	3.3	3.3	0.2	1.57																										
CSUA-1-XXX-CV1-PX-TW		2.4		10.2	411			7.3	3.3	3.3	3.3 0.2	1.57																										

#### **Model Number Selection**

XXX refers to the desired closing temperature. When the water temperature drops below this point the CircuitSolver® will begin to open, allowing water to easily enter the return line. For example, if you want 120°F desired return temperature and the CSUA is to be installed on a 3/4" line, the model number would be CSUA-3/4-120-PX-TW. To add optional check valve insert -CV1 directly after the temperature designation in the model number. Ex: CSUA-3/4-120-CV1-PX-TW.





FLOW RATE CALCULA	TION USING "Cv" FA	CTOR
$GPM = C_v \sqrt{\Delta P}$	$C_v = \sqrt{\frac{GPM}{\Delta P}}$	$\Delta P = \left[\frac{GPM}{C_V}\right]^2$

### **OPTIONAL CHECK VALVE**

#### **Features and Benefits**

- -100% factory tested drip tight operation
- -Snap fit design, no retainer needed
- -Extra-low head loss and low cracking pressure
- -External O-ring in groove
- Certifications
- -ANSI/ NSF 61

ITEM	MATERIAL
Сар	Glass filled Noryl
Guide	Glass filled Noryl
Plunger	Glass filled Noryl
Lip Spring	EPDM rubber
Spring	Stainless Steel AISI 301
O-ring	EPDM rubber

## 

### TYPICAL SPECIFICATION

- I. Furnish and install CIRCUITSOLVER® UNION ASSEMBLY with THERMOMETER as indicated on the plans. CIRCUITSOLVER® UNION ASSEMBLY with THERMOMETER shall be self-contained and fully automatic without additional piping or control mechanisms. Thermostatic valve shall be a CIRCUITSOLVER® as manufactured by ThermOmegaTech®, Inc., or equivalent.
  - A. CIRCUITSOLVER® shall regulate the flow of recirculated domestic hot water based on water temperature entering the CIRCUITSOLVER® UNION ASSEMBLY with THERMOMETER regardless of system operating pressure. As the water temperature increases the valve proportionally closes dynamically adjusting flow to meet the specified temperature.
    - 1. The CIRCUITSOLVER® never fully closes, even at the desired set point. There is always sufficient bypass flow back to the recirculating pump to prevent overheating or "dead heading" of the pump.
    - 2. CIRCUITSOLVER® is set at the factory for the desired return temperature. No field adjustments needed. Several temperature set points are available.
    - 3. CIRCUITSOLVER® UNION ASSEMBLY with THERMOMETER shall be available in ½", ¾", & 1" with Uponor ProPEX adapters at both ends.
- II. All components in the CIRCUITSOLVER® UNION ASSEMBLY with THERMOMETER are made with lead-free materials. The major components that make up the CIRCUITSOLVER® are constructed of type 300 series SS.
  - A. CIRCUITSOLVER® UNION ASSEMBLY with THERMOMETER shall be rated to 200 PSIG maximum working pressure.
    - 1. CIRCUITSOLVER® UNION ASSEMBLY with THERMOMETER shall be standard tapered female pipe thread, NPT with ProPEX adapters at both ends.
  - B. CIRCUITSOLVER® UNION ASSEMBLY with THERMOMETER shall be rated to 250°F (121.1°C) maximum working temperature.
  - C. CIRCUITSOLVER® UNION ASSEMBLY with THERMOMETER shall be NSF/ANSI/CAN 61 or 372 certified.
  - D. Thermal actuator shall be spring-loaded and self-cleaning, delivering closing thrust sufficient to keep orifice opening free of scale deposits.
- III. Installation of CIRCUITSOLVER® UNION ASSEMBLY with THERMOMETER shall be made by qualified tradesmen. Install CIRCUITSOLVER® UNION ASSEMBLY with THERMOMETER in each domestic hot water return piping branch beyond last hot water device in that branch.
  - A. Provide suitable strainer as indicated in piping detail shown on the drawings.
  - B. Provide suitable access panel as required in non-accessible ceilings and walls.
  - C. Pay close attention to flow arrow, especially with valves that have an integrated check valve.

