

CircuitSolver® Union Assembly Thermal Disinfection Dual Valve with Thermometer & Viega ProPress® Systems [Thermostatic balancing valve with union body, ball valves, thermometer, ProPress ends & two actuators]

# **SUBMITTAL**

JOB:	ORDER NO:	DATE:
	SUBMITTED BY:	DATE:
UNIT TAG:	APPROVED BY:	DATE:
CITY:	ENGINEER:	BUILDING TYPE:
STATE:	CONTRACTOR:	CONSTRUCTION TYPE:
COMPLETION DATE:		

## **DESCRIPTION**

CircuitSolver® is a thermostatic balancing valve that automatically and continuously adjusts flow to maintain the desired temperature in a domestic hot water supply line. Since the CircuitSolver® responds to water temperature to control the flow entering the recirculation line it eliminates the need to manually balance the system. The "CSUATD-D-PP-TW" version CircuitSolver® incorporates a second actuator to reopen the valve during a thermal disinfection process, an optional check valve, isolated ball valves, a thermometer and ProPress adapter fittings.


## **DIMENSIONS**

Item No.	Part Number	Description	Qty.
1	261-20X00X-XXX	OX-XXX CSUTD-D-1/2-XXX/ YYY-(CV1)	
2	92-162	½" X CL NIPPLE BRASS, LF	1
3	92-090	ADAPTER, ½" NPT x ½" ProPress	2
4	92-160	BALL VALVE, ½" MxF, LF	2
5	93-094-S	THERMOWELL ASSEMBLY	1
6	93-172	½" TEE, BRASS LF	1

Item No.	Part Number	Description	Qty.
1	261-30X00X-XXX	CSUTD-D-3/4-XXX/ YYY-(CV1)	1
2	92-026	¾" X CL NIPPLE BRASS, LF	1
3	92-091	ADAPTER, ¾" NPT x ¾" ProPress	2
4	92-158	BALL VALVE, ¾" MxF, LF	2
5	93-094-S	THERMOWELL ASSEMBLY	1
6	93-173	¾" X ½" TEE, BRASS LF	1

Item No.	Part Number	Description	Qty.
1	261-40X00X-XXX	CSUTD-D-1-XXX/YYY- (CV1)	1
2	92-044	1" X CL NIPPLE BRASS, LF	1
3	92-092	ADAPTER, 1" NPT x 1" ProPress	2
4	92-170	BALL VALVE, 1" MxF, LF	2
5	93-094-S	THERMOWELL ASSEMBLY	1
6	93-174	1" X 1/2" TEE, BRASS LF	1

\*ALL COMPONENTS ARE LEAD FREE





		Diameter (D)		Length (L)		Height (H)		Weight		Standard Balancing C <sub>v</sub>			Thermal Disinfection Balancing C <sub>v</sub>		Maximum Operating Pressure		Maximum Temperature	
Model No.	NPT	IN	MM	IN	ММ	IN	ММ	LBS	KG	OPEN	CLOSED	DESIGN	OPEN	CLOSED	PSIG	BAR	F٥	C°
CSUATD-D-1/2-XXX/170-PP-TW	1/2"	2.0	51	14.9	379	2.7	69	4.6	2.1	1.8	0.2	0.85	0.5	0.2				
CSUATD-D-1/2-XXX/170-CV1-PP-TW	1/2	2.0	51	14.9	3/9	2.7	69	4.6	2.1	1.8	0.2	0.85	0.5	0.2				
CSUATD-D-¾-XXX/170-PP-TW	3/4"	2.0	51	15.9	404	2.8	71	5.4	2.5	1.8	0.2	0.85	0.5	0.2	200	14	250	121
CSUATD-D-¾-XXX/170-CV1-PP-TW	3/4	2.0	51	15.9	404	2.0	/ '	5.4	2.5	1.0	0.2	0.65	0.5	0.2	200	'	200	121
CSUATD-D-1-XXX/170-PP-TW	1"	2.4	60	17.7	450	3.0	76	8.3	3.8	3.3	0.2	1.57	0.5	0.2	]			
CSUATD-D-1-XXX/170-CV1-PP-TW	l '	2.4	60	17.7	450	3.0	/ 6	0.3	3.0	3.3	0.2	1.57	0.5	0.2				

### Model Number Selection


XXX refers to the desired closing temperature for standard balancing. When the water temperature drops below this point the CircuitSolver® will begin to open, allowing water to easily enter the return line. The valve will start to reopen approximately 20°F above the standard balancing temperature and rebalance the system at 170°F. For example, if you want 120°F desired return temperature and the CSUATD-D-PP-TW is to be installed on a 3/4" line, the model number would be CSUATD-D-3/4-120-170-PP-TW. To add optional check valve insert -CV1 to the end of the model number. Ex. CSUATD-D-3/4-120-170-CV1-PP-TW



<sup>\*</sup>ALL COMPONENTS ARE LEAD FREE

<sup>\*</sup>ALL COMPONENTS ARE LEAD FREE





FLOW RATE CALCULA	ΓΙΟΝ USING "Cv" FA	ACTOR
$GPM = C_v \sqrt{\Delta P}$	$C_v = \sqrt{\frac{GPM}{\Delta P}}$	$\Delta P = \left[ \frac{GPM}{C_V} \right]^2$

#### **OPTIONAL CHECK VALVE Features and Benefits** -100% factory tested drip tight operation -Snap fit design, no retainer needed -Extra-low head loss and low cracking pressure -External O-ring in groove Certifications -ANSI/ NSF 61 ITEM **MATERIAL** Cap Glass filled Noryl Guide Glass filled Noryl Plunger Glass filled Noryl Lip Spring EPDM rubber Stainless Steel AISI 301 Spring EPDM rubber



O-ring

### TYPICAL SPECIFICATION

- I. Furnish and install CIRCUITSOLVER® as indicated on the plans. CIRCUITSOLVER® shall be self-contained and fully automatic without additional piping or control mechanisms. Valve shall be a CIRCUITSOLVER® as manufactured by ThermOmegaTech®, Inc. or equivalent.
  - A. CIRCUITSOLVER® shall regulate the flow of recirculated domestic hot water based on water temperature entering the CIRCUITSOLVER® regardless of system operating pressure. As the water temperature increases the valve proportionally closes dynamically adjusting flow to meet the specified temperature.
    - 1. CIRCUITSOLVER® never fully closes, even at the desired set point. There is always sufficient bypass flow back to the recirculating pump to prevent overheating or "dead heading" of the pump.
    - 2. CIRCUITSOLVER® is set at the factory for the desired return temperature. No field adjustments needed. Several temperature set points are available.
    - 3. CIRCUITSOLVER® Thermal Disinfection Dual Balancing Assembly with Thermometer shall be available in 1/2", 3/4" & 1" NPT with Viega ProPress adapter fittings at both ends.
  - B. CIRCUITSOLVER® Thermal Disinfection Dual Balancing Assembly with Thermometer and ProPress adapters allows for an additional balancing cycle at 170°F.
    - 1. The valve will start to re-open above the low temperature balancing set point to allow high temperature water through during a thermal disinfection process. The valve will rebalance at the second temperature set point.
- II. CIRCUITSOLVER® body and all internal components are made with lead-free materials with major components constructed of type 300 series SS.
  - A. CIRCUITSOLVER® shall be rated to 200 PSIG maximum working pressure.
    - 1. CIRCUITSOLVER® shall be standard tapered female pipe thread, NPT, with ProPress adapter fittings at both ends.
  - B. CIRCUITSOLVER® shall be rated to 250°F (121.1°C) maximum working temperature.
  - C. Thermal actuator shall be spring-loaded and self-cleaning, delivering closing thrust sufficient to keep orifice opening free of scale deposits.
- III. Installation of CIRCUITSOLVER® shall be made by qualified tradesmen. Install CIRCUITSOLVER® in each domestic hot water return piping branch beyond last hot water device in that branch.
  - A. Provide suitable line size isolation valves, unions, and strainer as indicated in piping detail shown on the drawings.
  - B. Provide suitable access panel as required in non-accessible ceilings and walls.
  - C. Pay close attention to flow arrow, especially with valves that have an integrated check valve.

