

CircuitSolver® Union Assembly Thermal Disinfection Dual Valve with Uponor ProPEX® Systems (CSUATD-D-PX) [Thermostatic balancing valve with union body, ball valves, ProPress ends & two actuators]

SUBMITTAL

JOB:	ORDER NO:	DATE:
	SUBMITTED BY:	DATE:
UNIT TAG:	APPROVED BY:	DATE:
CITY:	ENGINEER:	BUILDING TYPE:
STATE:	CONTRACTOR:	CONSTRUCTION TYPE:
COMPLETION DATE:		

DESCRIPTION


CircuitSolver® is a thermostatic balancing valve that automatically and continuously adjusts flow to maintain the desired temperature in a domestic hot water supply line. Since the CircuitSolver® responds to water temperature to control the flow entering the recirculation line it eliminates the need to manually balance the system. The "CSUATD-D-PX" version CircuitSolver® incorporates a second actuator to reopen the valve during a thermal disinfection process, an optional check valve, isolated ball valves, and Uponor ProPEX® adapter fittings.


DIMENSIONS

Item No.	Part Number	Part Number Description			
1	261-20X00X-XXX	CSUTD-D-1/2-XXX/ YYY-(CV1)	1		
2	92-116	ADAPTER, ½" NPT x ½" ProPEX	2		
3	92-160	BALL VALVE, ½" MxF, LF	2		

Item No.	Part Number	Description	Qty.	
1	261-30X00X-XXX	CSUTD-D-3/4-XXX/ YYY-(CV1)	1	
2	92-093	ADAPTER, ¾" NPT x ¾" ProPEX	2	
3	92-158	BALL VALVE, ¾" MxF, LF	2	

Item No.	Part Number	nber Description		
1	261-40X00X-XXX	CSUTD-D-1-XXX/YYY- (CV1)	1	
2	92-117	ADAPTER, 1" NPT x 1" ProPEX	2	
3	92-170	BALL VALVE, 1" MxF, LF	2	





		Diame	ter (D)	Leng	th (L)	Heigl	ht (H)	We	ight	Star	ndard Balan	cing C _v	Thermal D Balan	isinfection cing C _v	Maxi Operating	mum Pressure		mum erature
Model No.	NPT	IN	MM	IN	ММ	IN	ММ	LBS	KG	OPEN	CLOSED	DESIGN	OPEN	CLOSED	PSIG	BAR	°F	°C
CSUATD-D-1/2-XXX/170-PX	1/2"	1.8	46	12.6	320	1.8	46	3.8	1.7	1.8	0.2	0.85	0.5	0.2				
CSUATD-D-1/2-XXX/170-CV1-PX	1/2	1.8	46	12.0	320	1.8	40	3.8	1.7	1.8	0.2	0.85	0.5	0.2				
CSUATD-D-¾-XXX/170-PX	3/4"	2.0	51	13.9	353	2.0	51	4.0	1.8	1.8	0.2	0.85	0.5	0.2	200	14	250	121
CSUATD-D-3/4-XXX/170-CV1-PX	3/4	2.0	51	13.9	303	2.0	51	4.0	1.0	1.0	0.2	0.65	0.5	0.2	200		200	121
CSUATD-D-1-XXX/170-PX	1"	2.5	64	15.8	401	2.3	58	7.1	3.2	3.3	0.2	1.57	0.5	0.2				
CSUATD-D-1-XXX/170-CV1-PX	<u> </u>	2.5	04	13.0	+01	2.5		/	5.2	5.5	0.2	1.57	0.5	0.2				

Model Number Selection


XXX refers to the desired closing temperature for standard balancing. When the water temperature drops below this point the CircuitSolver® will begin to open, allowing water to easily enter the return line. The valve will start to reopen approximately 20°F above the standard balancing temperature and rebalance the system at 170°F. For example, if you want 120°F desired return temperature and the CSUATD-D-PX is to be installed on a 3/4" line, the model number would be CSUATD-D-3/4-120-170-PX. To add optional check valve insert -CV1 to the end of the model number, Ex. CSUATD-D-3/4-120-170-CV1-PX


^{*}ALL COMPONENTS ARE LEAD FREE

^{*}ALL COMPONENTS ARE LEAD FREE

^{*}ALL COMPONENTS ARE LEAD FREE








	- skeeper	
ITEM	DESCRIPTION	MATERIAL
1	Valve Body w/ Union Threads	300 series stainless steel
2	Insert - CircuitSolver®	300 series stainless steel
3	Spring	300 series stainless steel
4	Plug	300 series stainless steel
5	Thermal Actuator	300 series stainless steel
6	Carrier	300 series stainless steel
7	Union Nut	300 series stainless steel
8	O-ring	BUNA
9	Check Valve (optional)	GLASS FILLED NORYL
10	Insert - Female Threaded	300 series stainless steel

FLOW RATE CALCULATION USING "Cv" FACTOR							
$GPM = C_v \sqrt{\Delta P}$	$C_v = \sqrt{\frac{GPM}{\Delta P}}$	$\Delta P = \left[\frac{GPM}{C_{v}}\right]^{2}$					

OPTIONAL CHECK VALVE Features and Benefits -100% factory tested drip tight operation -Snap fit design, no retainer needed -Extra-low head loss and low cracking pressure -External O-ring in groove Certifications -ANSI/ NSF 61 ITEM **MATERIAL** Cap Glass filled Noryl Guide Glass filled Noryl Plunger Glass filled Noryl Lip Spring EPDM rubber Spring Stainless Steel AISI 301 EPDM rubber O-rina



TYPICAL SPECIFICATION

- I. Furnish and install CIRCUITSOLVER® as indicated on the plans. CIRCUITSOLVER® shall be self-contained and fully automatic without additional piping or control mechanisms. Valve shall be a CIRCUITSOLVER® as manufactured by ThermOmegaTech®, Inc. or equivalent.
 - A. CIRCUITSOLVER® shall regulate the flow of recirculated domestic hot water based on water temperature entering the CIRCUITSOLVER® regardless of system operating pressure. As the water temperature increases the valve proportionally closes dynamically adjusting flow to meet the specified temperature.
 - 1. CIRCUITSOLVER® never fully closes, even at the desired set point. There is always sufficient bypass flow back to the recirculating pump to prevent overheating or "dead heading" of the pump.
 - 2. CIRCUITSOLVER® is set at the factory for the desired return temperature. No field adjustments needed. Several temperature set points are available.
 - 3. CIRCUITSOLVER® Union Assembly Thermal Disinfection Dual Balancing Valve shall be available in 1/2", 3/4" & 1" NPT with ProPEX adapter fittings at both ends.
 - B. CIRCUITSOLVER® Union Assembly Thermal Disinfection Dual Balancing Valve with ProPEX adapters allows for an additional balancing cycle at 170°F.
 - 1. The valve will start to re-open above the low temperature balancing set point to allow high temperature water through during a thermal disinfection process. The valve will rebalance at the second temperature set point.
- II. CIRCUITSOLVER® body and all internal components are made with lead-free materials with major components constructed of type 300 series SS.
 - A. CIRCUITSOLVER® shall be rated to 200 PSIG maximum working pressure.
 - 1. CIRCUITSOLVER® shall be standard tapered female pipe thread, NPT, with ProPEX adapter fittings at both ends.
 - B. CIRCUITSOLVER® shall be rated to 250°F (121.1°C) maximum working temperature.
 - C. Thermal actuator shall be spring-loaded and self-cleaning, delivering closing thrust sufficient to keep orifice opening free of scale deposits.
- III. Installation of CIRCUITSOLVER® shall be made by qualified tradesmen. Install CIRCUITSOLVER® in each domestic hot water return piping branch beyond last hot water device in that branch.
 - A. Provide suitable line size isolation valves, unions, and strainer as indicated in piping detail shown on the drawings.
 - B. Provide suitable access panel as required in non-accessible ceilings and walls.
 - C. Pay close attention to flow arrow, especially with valves that have an integrated check valve.

